# Microlinea™ Recessed Series 5 -**Fluorescent**

(5 1/8" Luminous Aperture)




# $\overline{1/2}$ " or 5/8" Thick **Drywall Ceilings**


Type

Catalog Number


Project Name



**Drywall Overlap Flange** Shown with Flush Lens



**Drywall Spackle Flange** Shown with Flush Lens



**Drywall Spackle Flange** Shown with Parabolic Baffle





Emergency Battery Pack (975-1325 Lumens) (N/A for 2' or 3')

# Dim

## Dimmina

Fused Ballasts

GTD

Generator Transfer (N/A for 2' or 3')

Chicago Plenum

Damp Location Rapid Start Ballast

## Housing

Three piece extruded aluminum available in single sections up to 8' long in 2' increments. Standard flange finish is satin white.

#### **Optical Controls**

- (PB) 3/4" deep semi-specular aluminum parabolic baffle with blades on 1 1/2" centers
- (PBW) 3/4" deep white aluminum parabolic baffle with blades on 1 1/2" centers
- (LP) Flush clear extruded DR acrylic linear prismatic lens
- (TWA) Flush translucent white extruded DR acrylic lens
- (FC) Flush frosted clear extruded DR acrylic lens

#### Staggered Lamping

Staggered lamping is standard for all continuous rows. See Microlinea Row Guide Section.

Series

Die-formed from .020" thick aluminum and finished with a high reflectance white enamel.

Nominal Length:

See Microlinea Row Guide Section for

#### Ballast

Standard ballasts for T8 lamps are UL/CUL listed. Class P, HPF, electronic, universal 120/277volt, instant start with <10% THD.

#### Circuitry

All fixtures are factory pre-wired for a single circuit. Provision for multiple switching/circuiting is optional.

#### Wiring

All fixtures intended for continuous rows are provided with factory installed quick-connect wiring.

#### **Integral Controls**

Contact factory for daylight and/or occupancy sensor controls.

### Certification

All fixtures are UL/CUL listed for use in 'Dry Applications'. 'Damp Location' is optional.

Mountings TR = 1/4-20 Threaded Rod (By others) - (OF)

YK = Snap-in Yoke - (OF)
AC = Adjustable Aircraft Cable - (OF)

TR = 1/4"-20 Threaded Rod (By others) - (SF)

YK = Adjustable Yoke - (SF)

Voltage

120

277

347

# row lengths

# MLR5-1-18'-OF-YK-PB-120-T8-

# of Lamps

Ceiling Type

Drywall Overlap Flange SF1

Spackle Flange w/1/2" Drywall

SF5 Spackle Flange w/5/8" Drywall

**Optical Controls** 

PB Semi-Specular Parabolic Baffle

PBW White Parabolic Baffle

Linear Prismatic Lens Translucent White

Frosted Clear Lens

Acrylic Lens

#### Lamp Type SS (L/R) (Left/Right)

Lamp Row Switching (Common Neutral) (N/A for 2' or 3')

#### NI CKT

Night Light Circuit (Common Neutral) (N/A for 2' or 3')

**Emergency Circuit** (Separate Hot & Neutral) (N/A for 2' or 3')

#### EBPL

Emergency Battery Pack (635-700 Lumens) (N/A for 2' or 3')