



LUMINAIRE TESTING LABORATORY, INC.

SUSTAINING
MEMBER
of the
IESNA

905 Harrison Street · Allentown, PA 18103 · 610-770-1044 · Fax 610-770-8912 · www.LuminaireTesting.com

LTL NUMBER: 13168

DATE: 05-06-2008

PREPARED FOR: PRECISION ARCHITECTURAL LIGHTING

CATALOG NUMBER: MLP-I2/D1-4-W-OP/DLP-X-120-T5HO

LUMINAIRE: EXTRUDED ALUMINUM HOUSING, FORMED SPECULAR ALUMINUM UPPER AND LOWER REFLECTOR, CLEAR LINEAR PRISMATIC PLASTIC LOWER LENS, OPEN TOP.

LAMPS: THREE 54 WATT HIGH OUTPUT T5 LINEAR FLUORESCENT LAMPS RATED AT 4400 LUMENS EACH.

LAMP CATALOG NUMBER: PHILIPS F54T5/835/HO/ALTO AND PHILIPS F54T5/850/HO/ALTO

BALLASTS: TWO UNIVERSAL LIGHTING TECHNOLOGIES B254PUNV-D

NOTE: THIS TEST WAS CALCULATED USING MEASURED DATA FROM LTL TEST NUMBERS 12730 AND 12732.

LUMEN TO CANDELA RATIO USED = 9.18


TOTAL INPUT WATTS =161.3 AT 120.0 VOLTS

THE 0 DEGREE PLANE IS PERPENDICULAR TO THE LAMPS.

CANDELA DISTRIBUTION										FLUX
0.0	22.5	45.0	67.5	90.0	112.5	135.0	157.5	180.0		
0	789	789	789	789	789	789	789	789	789	
5	700	705	729	756	788	810	826	828	828	73
15	534	537	576	655	740	803	817	863	871	202
25	477	474	482	515	643	743	872	930	948	310
35	404	405	428	403	508	681	842	925	934	380
45	292	296	326	348	358	605	771	834	835	395
55	224	215	217	252	227	491	629	635	606	345
65	162	152	143	143	136	347	419	384	360	245
75	94	84	76	65	60	170	196	179	164	127
85	26	22	18	12	10	31	36	34	26	29
90	11	11	9	3	1	2	2	2	7	
95	75	161	135	121	112	117	128	141	92	135
105	360	522	600	623	625	619	606	514	383	591
115	694	936	967	1015	1052	1025	967	882	714	939
125	1010	1377	1285	1388	1395	1386	1280	1365	1025	1178
135	1304	1759	1778	1667	1638	1657	1763	1766	1324	1286
145	1552	1848	2122	2101	2096	2096	2112	1920	1566	1240
155	1756	1914	2260	2366	2373	2369	2302	1919	1770	993
165	1897	2002	2074	2175	2244	2207	2081	2004	1894	594
175	1966	1972	2021	2034	2034	2042	2032	1991	1966	193
180	1968	1968	1968	1968	1968	1968	1968	1968	1968	

ZONAL LUMEN SUMMARY

ZONE	LUMENS	%LAMP	%FIXT
0- 30	585	4.4	6.3
0- 40	965	7.3	10.4
0- 60	1705	12.9	18.4
0- 90	2106	16.0	22.8
90-120	1665	12.6	18.0
90-130	2842	21.5	30.7
90-150	5368	40.7	58.0
90-180	7147	54.1	77.2
0-180	9253	70.1	100.0



TOTAL LUMINAIRE EFFICIENCY: 70.1%

CIE TYPE: SEMI-INDIRECT

PLANE: 0-DEG 90-DEG 180-DEG

SPACING CRITERIA: 0.8 1.1 1.7

Approved By: MG

THIS REPORT BASED ON LM-41 AND OTHER PERTINENT IESNA PROCEDURES.



LUMINAIRE TESTING LABORATORY, INC.

SUSTAINING
MEMBER
of the
IESNA

905 Harrison Street · Allentown, PA 18103 · 610-770-1044 · Fax 610-770-8912 · www.LuminaireTesting.com

LTL NUMBER: 13168

DATE: 05-06-2008

PREPARED FOR: PRECISION ARCHITECTURAL LIGHTING


ZONAL LUMEN SUMMARY

0- 5	19.
5- 10	55.
10- 15	86.
15- 20	116.
20- 25	143.
25- 30	167.
30- 35	184.
35- 40	196.
40- 45	200.
45- 50	195.
50- 55	183.
55- 60	162.
60- 65	137.
65- 70	108.
70- 75	79.
75- 80	49.
80- 85	24.
85- 90	5.
90- 95	16.
95-100	118.
100-105	245.
105-110	346.
110-115	431.
115-120	508.
120-125	567.
125-130	611.
130-135	635.
135-140	651.
140-145	640.
145-150	600.
150-155	537.
155-160	456.
160-165	350.
165-170	243.
170-175	145.
175-180	47.

PLANE: 0-DEG 90-DEG
 LUMINOUS LENGTH: 2.875 48.000

LUMINANCE IN CANDELA PER SQUARE METER

ANGLE IN DEG	AVERAGE 0-DEG	AVERAGE 45-DEG	AVERAGE 90-DEG
0	8861.	8861.	8861.
45	4638.	5178.	5686.
55	4386.	4249.	4445.
65	4305.	3800.	3614.
75	4079.	3298.	2604.
85	3350.	2320.	1289.





LTL NUMBER: 13168
PREPARED FOR: PRECISION ARCHITECTURAL LIGHTING

DATE: 05-06-2008

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

EFFECTIVE FLOOR CAVITY REFLECTANCE 0.20

Table with 17 columns: RC, RW, and four groups of four values each for ceiling reflectance levels 80, 70, 50, 30, 10, and 0. Rows represent different room heights from 0 to 10.

NOTE: THE ZONAL CAVITY CALCULATION TECHNIQUE IS ACCURATE WHEN LUMINAIRES WITH SYMMETRIC CANDELA DISTRIBUTIONS ARE EMPLOYED AND WHEN THE LUMINAIRES ARE LOCATED SYMMETRICALLY THROUGHOUT THE ROOM. THIS UNIT HAS SPECIAL CHARACTERISTICS AND THEREFORE THESE COEFFICIENTS SHOULD BE USED WITH CAUTION.

THIS TEST WAS CONDUCTED USING RELATIVE PHOTOMETRY TECHNIQUES ACCORDING TO STANDARD IESNA PROCEDURES. THE USER MUST THEREFORE USE CAUTION IN THE FOLLOWING SITUATIONS: 1) THIS TEST WAS PERFORMED USING A SPECIFIC BALLAST/LAMP COMBINATION. EXTRAPOLATION OF THESE DATA FOR OTHER BALLAST/LAMP COMBINATIONS MAY PRODUCE ERRONEOUS RESULTS. 2) ACCORDING TO IESNA PROCEDURES, THE BALLAST(S) AND LAMP(S) ARE PRESUMED TO PRODUCE 100% OF RATED OUTPUT. AN APPROPRIATE BALLAST FACTOR MUST BE APPLIED TO THE LUMEN OUTPUT RATINGS AND LUMINOUS INTENSITY VALUES GIVEN. 3) THIS TEST WAS CONDUCTED IN A CONTROLLED LABORATORY ENVIRONMENT WHERE THE AMBIENT TEMPERATURE WAS HELD AT 25°C ±1°C. FIELD PERFORMANCE MAY DIFFER PARTICULARLY IN REGARDS TO CHANGE IN LUMINOUS OUTPUT AS A RESULT OF DIFFERENCE IN AMBIENT TEMPERATURE AND METHOD OF MOUNTING THE LUMINAIRE.